

DRAWING NUMBER

- ## ELECTRICAL
1. For electrical specifications see Standard #44)
  2. All electrical conduit to be insulated.
  3. All communication cables to be otherwise noted.
  4. Device plates to be removed from plates for telephone.
  5. All floor outlets to be removed and not re-used as per specification.
  6. All panel direct wiring to be removed.
  7. All telephone equipment to be removed.
  8. The contractor to be responsible for which are to be removed and architectural to be replaced.
  9. All lighting fixtures to be removed, conduit, wiring to be re-used.
  10. Coordinate re-specifications with electrical engineer.
  11. Ground every #6 copper ground pedestal with ground rod.
  12. For thermostat specifications see Standard #44)
  13. For exact location of equipment see architectural drawings.